



NOTES

- 1. TERMINAL BOARDS
- TB30 = 30 AMP @ 600V
- TB31 = 100 AMP @ 300VAC
- TB32 = 200 AMP @ 600VAC
- X1, X2, X3 = 200 AMP @ 300 VAC
- TB101 = 30 AMP @ 600V

LEGEND

(D) CLASS 1E, DIV. 1

REF:

B-208-216 SH.28 - E.D.

SCHEMATIC - POWER CHASSIS

DESIGNED BY	DATE	DESIGNED BY	DATE	APPROVED BY	DATE
SV	3-24-77	WJF	3-25-77		
BASLER ELECTRIC CO.		91183 015			
OVERLAND, ILLINOIS					

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO.
PERRY NUCLEAR POWER PLANT UNIT 1
ELECTRICAL-ELEMENTARY DIAGRAM
STANDBY DIESEL GENERATOR
GENERATOR CONTROL
POWER CHASSIS SCHEMATIC
DIVISION 1 IHSI. P055A

REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE
A		WJC	RAM	DES	10-6-81																		

ELEM DATA IHSI-PO55A

READING PA.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS	DATE	1-15-77
WORK ORDER	044548-000	DATE	1-15-77
MADE	WJC	DATE	1-15-77
CHKD.	WJC	DATE	1-15-77
DR. APP.	WJC	DATE	1-15-77
DATE			
DRAWING NUMBER	B-208-216	REV	34
SYSTEM	MI. NO.	DATE	

Rids

8212210584

