


- NOTES:
1. USE FOR BOXES WITH A MAXIMUM DIMENSION OF 24".
  2. BOX ATTACHMENT BOLT-DIAMETER SHALL BE  $\frac{3}{8}$ " MINIMUM.
- UNISTRUT NUTS SHALL BE USED. A MINIMUM OF FOUR BOLTS PER BRACKET AT EACH CORNER MAY BE USED PROVIDED THE DIST. FROM CENTERLINE OF BOLT TO EDGES OF BOX ARE  $\leq 3$  INCHES. OTHERWISE USE DETAILS FOR TYPES 9A OR 9B AS APPLICABLE.

TYPE 9C SUPPORT

9-2-81	INCORD CENSUS REV-TITLE BLOCK	11/11/81	800-22	JAB AND	JAB AND	JAB AND	JAB AND
9-2-81	ISSUED FOR REGULARIZATION						
9-2-81	REVALUATION						
9-2-81	ISSUED FOR CONSTATE WAS SHIT 702						
NO.	DATE	REVISIONS	BY	CHG.	GROUP LEAD	GROUP SUPT.	CHIEF ENGINEER
SCALE NAME		DESIGNED		DRAWING			
ORIGIN	 MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY CONDUIT AND TRAY NOTES, SYMBOLS AND DETAILS			JOB NO. 7220 DRAWING NO. E-278 (a) SH. 602			

CERTIFICATE OF MICROFILMING

"I certify that the image contained on this frame was made in the normal and regular course of business on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming by Bechtel Power Corporation."

4/11/83 Rose Spies Sue Crackett  
Date Camera Operator Cont. Supvr.



# PDR RIDS

8401/00028

