

17"
11"
8.5"
8.5"
11"
17"

17"
11"
8.5"
8.5"
11"
17"

EXCEPTIONS LIST

SUPPORT No.	TYPICAL SUPPORT	CONDUIT(S)	APPROX. LOCATION	EXCEPTION(S)
1620	20	BLOCK (1)		<p>CONDUIT DEAD END DISTANCE IS 3'</p> <p>HAS TYPE 12B SUPT ON TS</p> <p>2 HORIZONTAL MEMBERS</p> <p>MAX. LOAD = 1130#</p> <p>NO LONGITUDINAL BRACING</p> <p>FCR E-2750</p> <p>FCR E-2622</p>
		2BJB065		
		2BJB054		
		2BJP009		
		2BJP010		
		2BTB027		
		2AJB065		
		<p>⚠</p> 2BJB020 2BJP006 2BTB013 2BJB061 2BJB015		
		BLOCK (1)		
		PLUS		
		2BJB096 AUX. BLDG 2BJP007 ELEV. 614 2BJB030 COL. LINE 2BKA023 1-73 AND 2BTB009 2-6" S. OF 2BTB008 (F)		
		1621		
PLUS				
2BJB030 AUX. BLDG 2BKA023 ELEV. 614 2BTB009 COL. LINE 1BJA022 1-73 AND 2BTB014 2-6" S. OF (F)				

This drawing and the design it contains are the property of BECHTEL. They are hereby loaned and/or the borrower's express agreement that it will not be reproduced, copied, loaned, exhibited, or used in any way without the written consent given by the lender.

11-1-81	GROUP	FOR E-2750	SID	RMW	PS	AW	JK	LD	WJ	OUT
6-2-81	GROUP	FOR E-2622	SID	PT	PS	AW	JK	LD	WJ	OUT
5-15-81	GROUP	FOR E-2288	SID	PT	PS	AW	JK	LD	WJ	OUT
NO.	DATE	ISSUED FOR CONSTRUCTION	BY	CHEF.	GROUP LEAD.	GROUP SUPV.	PROJ. ENGR.	CHIEF ENGR.		
SCALE	N/A	DESIGNED	P. R. GALLAGHER	BY	CHEF.	GROUP LEAD.	GROUP SUPV.	PROJ. ENGR.	CHIEF ENGR.	
ORIGIN		MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY CONDUIT AND TRAY NOTES, SCHEDULES AND DETAILS			DRAWN	P. R. GALLAGHER				
					JOB No.	7220				
					DRAWING No.	E-428(Q) Sh. III				
					REV.	2				

PRC
APERTURE
CARD

10X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

11-16-82
DATE
JAN BUCKLEY
CAMERA OPERATOR
REPROGRAPHICS
G-1345

8302020507

RIDS

