

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

16X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

11-30-88 TRAVIS BOSTON 28 88-11

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and periods as permitted by any written consent given by the lender to the borrower.

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CUBICLE No.	SCHEME No.	BREAKER			STARTER		WIRE SIZE (AWG)	LOAD KVA	FULL LOAD AMPS	CONT. AMPS.	
						FRAME SIZE	TRIP RATING	INST. TRIP SETTING	SIZE	TYPE					REMARKS
3	PUMP MOTOR COOLING FAN OV-70A	OV-70A	1B6301	E-46B	1AB6301	100	SOL		2	1A-27	SEE NOTE 1	#6	15HP	19.5	
5	SERVICE WATER STRAINER OF-75A	OF-75A	1B6302	E-170	1AB6302	100	TD		1	1A-27		#14	3HP	6	
0	SPACE		1B6303		1AB6303										
8	SW PUMP PIT SLUICE GATE OM-36A	OM-36A	1B6304	E-191	1AB6304	100	SOL		2	2C1		#6	13.2HP	16.9	
1	SERVICE WATER BLDG. MCC 0B69	0B69	1B6305	E-80	1AB6305	100	100			CB	SEE NOTE 2	#2			
2	SPACE HEATER DISCONNECT		1B6306	E-80	0AY8520	100	15			CB		#14			
C	SPACE		1B6307		1AB6307										
T	SPACE		1B6308		1AB6308										
I	SPACE		1B6309		1AB6309										
↓	SPACE		1B6310		1AB6310										
↓	SPACE		1B6311		1AB6311										

1	2
A 1B6305	A TERM COMP
B 1B6303	B 1B6301
C 1B6304	C 1B6302
D 1B6306	D 1B6303
E 1B6307	E 1B6310
F 1B6308	F 1B6311

CLASS IE 460V MOTOR CONTROL CENTER No. 1863
LOCATION: SERVICE WATER BLDG.
EL. 634-5
REF. DWG: 7220-57-132

NOTE: 1. CONTROL TRANSFORMER RATING SHALL BE 150 VA.
2. CIRCUIT BREAKER WITH REMOTE OPERATOR.

BECHTEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
CLASS IE 460V MOTOR CONTROL CENTER SCHEDULES UNIT 1		
JOB No.	DRAWING No.	REV.
7220	E-17(Q)SH.14	3

P.R.C. APERTURE CARD

RIDS

8302030246

