

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

16X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's separate agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and private use permitted by any written permission given by the lender to the borrower.

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CONT. No.	SCHEME No.	BREAKER			STARTER			WIRE SIZE (AWG)	LOAD KVA or H.P.	FULL LOAD AMPS	CONT. AMPS
						FRAME SIZE	TRIP/CONT RATING AMPS	INST. TRIP SETTING	FL POS	SIZE	TYPE				
0	SERVICE WATER FAN OVV-50B	OVV-50B	BB6401	E-468	BB6401	100	50L		2	1A-2	SEE NOTE #6	#6	15HP	19.5	
0	SERVICE WATER STRAINER OF-75B	OF-75B	BB6402	E-190	BB6402	100	10		1	1A2-2		#14	3HP	6	
0	SPACE	SPACE	BB6403		BB6403										
0	SW PUMP SLUICE GATE OM-96B	OM-96B	BB6404	E-191	BB6404	100	50L		2	2C1		#6	13.2HP	16.9	
1	SERVICE WATER BUILDING MCC OB6B FEED	OB-6B	BB6405	E-200	BB6405	100	100				SEE NOTE #2				
2	SPACE HEATER DISCONNECT			E-80	OB-8420	100	15					#14			
0	SPACE														
0	SPACE	SPACE	BB6407		BB6407										
0	SPACE	SPACE	BB6408		BB6408										
0	SPACE	SPACE	BB6409		BB6409										
0	SPACE	SPACE	BB6410		BB6410										
0	SPACE	SPACE	BB6411		BB6411										

	1	2
A	186402	A TERM COMP
B	186403	B
C	186404	C
D	186407	D
E	186408	E
F	186409	F
G	186410	G
H	186411	H

CLASS IE 460V MOTOR CONTROL CENTER No 1864

LOCATION: SERVICE WATER BUILDING EL. 634'-6"

REF. DWG: 7220-E7-133

NOTE 1: CONTROL TRANSFORMER RATING SHALL BE 150VA
2: CIRCUIT BREAKER WITH REMOTE OPERATOR

BECHTEL
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

CLASS IE 460V MOTOR CONTROL
SCHEDULES UNIT 1

JOB No.	DRAWING No.	REV.
7220	E-17(0)SHJ5	8

PRO APERTURE CARD

RIDS

8302030249

