

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on this loan, it is agreed that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and phrase use permitted by the loaner to the borrower.

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CONT. No.	SCHEME No.	BREAKER			STARTER		WIRE SIZE (A.W.G.)	LOAD KVA	FULL LOAD AMPS	CONT. AMPS.
						FRAME SIZE	TRIP	INST. TRIP	STARTER TYPE	REMARKS				
2	SPACE HEATER DISCONNECT		188901	E-80	CR13320	15			CB					
2	SPACE	SPACE	188902		1A28102									
2	SPACE	SPACE	188903		1A28103									
2	SPACE	SPACE	188904		1A28104									
2	POWER OPERATED ATMOSPHERIC VENT VALVE 1PV3100A1	1PV3100A1	188905	E-352	1A28105	100	3		2A	#14	33HP			
1	DELETED													
2	SPACE	SPACE	188907		1A28107									
1	DELETED													
4	AUX. EQUIPMENT ROOM UNIT COOLER QVM-108A	QVM108A	188909	E-452	1A28109	100	10		1A	#10	3HP			
2	CEW SYS. VLV. 1M0-16006A	1M0-16006A	188910	E-213	1A28110	100	5		2C1	3/4" #14	67HP			
3	POWER OPERATED ATMOSPHERIC VENT VALVE 1PV3100B1	1PV3100B1	188911	E-352	1A28111	100	3		2A	#14	33HP			

1	TERM COMP.	A
B	188907	
C	188902	
D	188903	
E	188904	
F	188905	
G	188909	
H	188910	
I	188911	

460V MOTOR CONTROL CENTER No. 1889
 LOCATION: AUX. BLDG.-SM.GEAR RM.-EL. 614'-0"
 REF. DWG: 7220-E7-204

BECHTEL
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

CLASSIE 460V MOTOR CONTROL CENTER
SCHEDULES UNIT 1

JOB No.	DRAWING No.	REV.
7220	E-17(05)16	5

16 X

CERTIFICATE OF MICROFILMING
 "I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation."
 10-20-87 DATE Dim Smith CAMERA OPERATOR Sue Crockett CONTRACTOR SUPERVISOR

PRO APERTURE CARD

RIDS

8302020251

