

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the printed copy and photos as permitted by any written consent given by the issuer of this drawing.

10-20-87 ADD REMARKS:
 2-25-87 REV. HP JONGERDUN#16
 10-12-76 ISSUED FOR CONSTRUCTION

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CONT. No.	SCHEME No.	BREAKER				STARTER		WIRE SIZE (AWG)	LOAD KVA or H.P.	FULL LOAD AMPS.	CONT. AMPS.
						FRAME SIZE	TRIP CURR. SETTING	DIST. TYPE	POS.	SIZE	TYPE				
7	CONTROL ROOM AIR HANDLING UNIT HEATER, OVM-018	OVM-018	OB4625	E-45	OBP4625	100	100			1	CB	#2	405KW	70.3	
8	EMERGENCY FUEL AREA EXHAUST FAN OVV-56B	OVV-56B	OB4626	E-45	OBP4626	100	150			4	CB	#2	17HP	96	
0	SPACE	SPACE	OB4627		OBP4627										
5	CONTROL RM. MAKEUP DEHUMIDIFIER HEATER OVE-63B	OVE-63B	OB4628	E-45	OBP4628	100	25				CB	#6	15KW	22.14	
0	SPACE	SPACE	OB4629		OBP4629										
0	SPACE	SPACE	OB4630		OBP4630										
6	INSTRUMENT TRANSFORMER OX-58	OX-58	OB4631	E-97	OBP4631	100	60				CB	2L#2	25KVA	52.1	
2															
2															

G	7
A	A
OB4625	OB4627
D	OB4628
OB4628	
D	
OB4630	
D	
OB4631	
D	

CLASSIE 460V MOTOR CONTROL CENTER No. OB46
 LOCATION: AUX BLDG AREA 3 EL. 007'-0"
 REF. DWG: 7220-E7-30

BECHTEL
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

CLASS IE 460V MOTOR CONTROL CENTER
SCHEDULE UNIT 2 & COMMON

JOB No.	DRAWING No.	REV.
7220	E-160	SH17

16X

CERTIFICATE OF MICROFILMING

"I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation."

10-20-87 Pam South Sue Crockett
 DATE CAMERA OPERATOR CONTRACTOR SUPERVISOR

PRG APERTURE CARD

RIDS

8302030291

