

17"
11"
8.5"
8.5"
11"
17"

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and private use permitted by any written consent given by the lender to the borrower.

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CONT. No.	SCHEME No.	BREAKER			STARTER			WIRE SIZE (AWG)	LOAD KVA	FULL LOAD AMPS	CONT. AMPS.
						FRAME SIZE	TRIP/CONT. RATING	INST. TRIP SETTINGS	POB SIZE	TYPE	REMARKS				
8	SERVICE WATER SUPPLY FAN OVV-90C	OVV-90C	2B6301	E-468	2AB6301	100	50L		2	4-27	NOTE 1	#6	15HP	19.5	
5	SERVICE WATER STRAINER OF-75C	OF-75C	2B6302	E-190	2AB6302	100	10		1	1RZ		#14	3HP	6	
0	SPACE	SPACE	2B6303		2AB6303										
8	SW PUMP PIT SLUICE GATE OM-86C	OM-96C	2B6304	E-191	2AB6304	100	50L		2	2C1		#6	13.2HP	16.9	
1	SERVICE WATER BLDG MCC OB69	OB69	2B6305	E-80	2AB6305	100	100			CP	NOTE 2	#2			
2	SPACE HEATER DISCONNECT		2B6306	E-80	DAY8521		15			CB		#14			
0	SPACE	SPACE	2B6307		2AB6307										
	SPACE	SPACE	2B6308		2AB6308										
	SPACE	SPACE	2B6309		2AB6309										
	SPACE	SPACE	2B6310		2AB6310										
	SPACE	SPACE	2B6311		2AB6311										

1	2
A	A
286302	286305
B	B
286303	286301
C	C
286304	286302
D	D
286306	286307
E	E
286307	286310
F	F
286308	286311

CLASS 1E 460V MOTOR CONTROL CENTER No. 2863
 LOCATION: SERVICE WATER BUILDING EL. 634'-6"
 REF. DWG: 7220-E7-134
 NOTE: CONTROL TRANSFORMER RATING SHALL BE 150VA
 2. CIRCUIT BREAKER WITH REMOTE OPERATOR

BECHTEL
 ANN ARBOR, MICHIGAN
 MIDLAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY
 CLASS 1E 460V MOTOR CONTROL
 SCHEDULES UNIT 24 COMMON

JOB No.	DRAWING No.	REV.
7220	E-16(Q)SH-8	8

PRO APERTURE CARD

16X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

11-30-82 DATE
 F. S. Schmitt OPERATOR

17"
11"
8.5"
8.5"
11"
17"

RIDS

8302030292

