

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

16X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.


REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CONT. BUS No.	DNG. No.	SCHEME No.	BREAKER			STARTER			WIRE SIZE (AWG)	LOAD KVA	FULL LOAD AMPS	CONT. AMPS.
							FRAME SIZE	TRIP CONT. RATING	INST. TRIP SETTING	POB	SIZE	TYP				
B	SERVICE WATER SUPPLY FAN QVV-90D	QVV90D	286401	E-468	2886401	100	50L			2	1A2	NOTE 1	#6	13HP	19.5	
V	SERVICE WATER STRAINER OF-75D	OF-75D	286402	E-90	2886402	100	10			1	1H2		#14	3HP	6	
0	SPACE		286403		2886403											
8	SW PUMP PIT SLUICE GATE QM-96D	QM-96D	286404	E-191	2886404	100	50L			2	2-1		#6	13.2HP	16.9	
F	SERVICE WATER BUILDING MCC OB6B	OB6B	286405	E-210	2886405	100	100				CB	NOTE 2	#2			
2	SPACE HEATER DISCONNECT		286406	E-80	08Y8421	100	13				CB		#14			
0	SPACE		286407		2886407											
T	SPACE		286408		2886408											
T	SPACE		286409		2886409											
T	SPACE		286410		2886410											
T	SPACE		286411		2886411											

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and not the borrower's. Any reproduction, copying, loaning, exhibiting, or use of any part hereof in any form or by any means without the prior written consent of BECHTEL is prohibited. This drawing is issued for construction.

1	2
A	A
TERM	286405
COMP.	B
286403	286401
C	C
286404	286402
D	D
286406	286409
E	E
286407	286410
F	F
286408	286411

CLASS 1E 460V MOTOR CONTROL CENTER No 2864
LOCATION: SERVICE WATER BUILDING EL 634-6"
REF. DWG: 7220-E7-135

NOTE: 1 CONTROL TRANSFORMER RATING SHALL BE 150 VA
2 CIRCUIT BREAKER WITH REMOTE OPERATOR

BECHTEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
CLASS 1E 460V MOTOR CONTROL CENTER SCHEDULES UNIT 2 & COMMON		
	JOB No. 7220	REV. E-18(Q)SH19 8

P.R.C.
APERTURE
CARD

RIDS

830203 0293

