

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and for the use permitted by the lender in its agreement.

REV.	LOAD DESCRIPTION	EQUIP. No.	MCC No.	CUBICLE No.	CONT. No.	SCHEME No.	BREAKER				STARTER		WIRE SIZE (AWG)	LOAD KVA	FULL LOAD AMPS.	CONT. AMPS.
							FRAME SIZE	TRIP SETTING	INST. TRIP	TRIP TYPE	STARTER TYPE	REMARKS				
1	SPACE HEATER DISCONNECT															
1	SPACE															
1	SPACE															
1	SPACE															
1	POWER OPERATED ATMOSPHERIC VENT VALVE 2PV3200A1	2PV3200A	2B8901	E352	2B8901	100	3			1	2A	#14	33HP			
0	DELETED															
1	SPACE															
0	DELETED															
2	AUX. EQUIPMENT ROOM UNIT COOLER OVM-109A	OVM-109A	2B8909	E452	2B8909	100	10			1	1A	#10	3HP			
1	CCW SYSTEM VALV 2MO-17006A	2MO-17006A	2B8910	E413	2B8910	100	5			1	2C1	3/16"	6HP			
1	POWER OPERATED ATMOSPHERIC VENT VALVE 2PV3200B1	2PV3200B	2B8911	E352	2B8911	100	3			1	2A	#14	33HP			
2	DELETED															

4	2
TERM COMP	A
B	2B8901
C	2B8902
D	2B8903
E	2B8904
F	2B8905
G	2B8906
H	2B8907
I	2B8908
J	2B8909
K	2B8910
L	2B8911

460V MOTOR CONTROL CENTER No. 2B89
 LOCATION: AUX BLDG-SW GEAR RM-EL 414-C
 REF. DWG: 7220-E7-205

BECHTEL
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

CLASS: 460V MOTOR CONTROL CENTER
SCHEDULES UNIT 2 + COMMON

JOB No.	DRAWING No.	REV.
7220	E JIB(2) SH 24	3

16X

CERTIFICATE OF MICROFILMING
 "I certify that the image contained on this frame was made in the normal and regular course of business, on the data stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation".
 DATE: 10-20-87
 CAMERA OPERATOR: Pam Smith
 CONTRACTOR SUPERVISOR: Sue Crockett

PRO APERTURE CARD

RIDS

8302030299

