

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and through use permitted for any written consent given by the lender to the borrower.

REV.	LOAD DESCRIPTION	EQUIP. No.	CUBICLE No.	CONT. No.	SCHEDULE No.	BREAKER		STARTER		WIRE SIZE (AWG)	LOAD KVA	FULL LOAD AMPS	CONT. AMPS.
						FRAME SIZE	TRIP SETTINGS	FILE	REMARKS				
1	SPACE HEATER DISCONNECT		289001	E-60	08Y3706		15		CB				
2	CONTROL XFRM. FOR CUBICLE 289010		289002		289002								
1	SPACE		289003		289003								
1	SPACE		289004		289004								
1	POWER OPERATED ATMOSPHERIC VENT VALVE 2M3200A2		289005	E-367	289005	100	3		2A	#14	.33HP		
0	DELETED		289006		289006								
1	SPACE		289007		289007								
0	DELETED		289008		289008								
2	AUX. EQUIPMENT RM. UNIT COOLER OVM-109B		289009	E-452	289009	100	10		1A	#10	3HP		
1	CCW SYSTEM No. 2M0-1700GB		289010	E-313	289010	100	5		2A	#14	.67HP	1.1	
1	POWER OPERATED ATMOSPHERIC VENT VALVE 2PY3200B2		289011	E-352	289011	100	3		2A	#14	.33HP		
2	DELETED												

1	289007
2	289001
C	289009
D	289009
E	289002
F	289011

460V MOTOR CONTROL CENTER No. 2890
 LOCATION: AUX. BLDG. - SW GEAR RM. - EL. 614'-0"
 REF. DWG: 7220-E7-207

BECHTEL
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

460V MOTOR CONTROL CENTER
SCHEDULE UNIT 2 & COMMON

DES. No.	DRAWING No.	REV.
7220	E. 18' (G) 25	3

16X

CERTIFICATE OF MICROFILMING
 "I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation."

10-30-87 Pam Smith Sue Cosmelt
 DATE CAMERA OPERATOR CONTRACTOR SUPERVISOR

PRO APERTURE CARD

RIDS

8302030301

