

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

The drawing and this page are copies of the original drawing. They are not to be used for reproduction. Any reproduction of this drawing without the written consent of the originator is prohibited. This drawing is the property of the originator and is not to be distributed outside the organization.

CIRCUIT NO.		CABLE SIZE	DESTINATION	SCHEME CABLE NO.	SERVICE DESCRIPTION
01	50	2/C#5	2C42	20Y1401A	NI-RPS SUBSYSTEM 4
02	20	2/C#10	2C43	20Y1402A	ESFAS ANALOG SENSORS
03	20	2/C#10	2C30	20Y1403A	RCP-PC/MR MONIT SYS. INSTR.
04	20	2/C#10	2C45	20Y1404A	ECC/S ANALG SUBSYSTEM "D"
05	20	2/C#10	2C166	20Y1405C	BOP-ESF (FOXBORO) INSTR.
06	50	2/C#6	2C14	20Y1406A	AUX FEED WTR. ISOLATION RELAYS
07	20	2/C#10	2C46	20Y1407A	ISOLATION RELAY CABINET
08	20	2/C#10	2C32	20Y1408A	SAFETY RELATED DISPLAY CABINET
09	20	2/C#10	2C7	20Y1409A	ISOLATION RELAY AUX. PWR. SPLY
10	20	2/C#10	2R1Y8441	20Y1410A	RADIATION MONITOR
11	20	2/C#10	2R1Y65148	20Y1411A	
12	20	2/C#10	2R1Y72470	20Y1412A	
13	20	2/C#10	2C447D	20Y1413A	ARTS CABINET CH'D"
14	20	2/C#10		20Y1414B	SPARE
15	20	2/C#10		20Y1415A	
16	20	2/C#10		20Y1416A	
17	20	2/C#10		20Y1417A	
18	20	2/C#10		20Y1418A	

  

10/95	CKT. 14 WAS SPARE REV. CKT. 13	ENG	CHK	APP	DATE
10/95	DELETE CKT 14	ENG	CHK	APP	DATE
24-77	ISSUED FOR CONSTRUCTION	SP	IP	APP	DATE
NO.	DATE	BY	CHK	APP	DATE
SCALE	NONE	DESIGNED	IP	DRAWN	SP
ORIGIN	120V AC DISTRIBUTION PANELS MIDLAND PLANT UNIT #2 AND COMMON			JOB NO.	7220
				DRAWING NO.	REV.
				E-32(Q)SH.8	13

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to respecphotopies.

PRO APERTURE CARD

RIDS

8302030453

