

17"
11"
8.5"
8.5"
11"
17"

17"
11"
8.5"
8.5"
11"
17"

This drawing and the design it carries are the property of Electric L.L. They are hereby loaned to you on the borrower's best representation that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and scope permitted by any written consent given by the lender to the borrower.

BREAKER					CABLE SIZE	DESTINATION	SCHEME CABLE NO.	SERVICE DESCRIPTION
NO.	FRAME	TRIP						
01	100	20	2/C #10	IRIY5367B	OB3701A	RADIATION MONITOR		
02	100	20	2/C #10		OB3702A	SPARE		
03	100	20	2/C #10	ORLY5462B	OB3703A	RADIATION MONITOR		
04	100	20	2/C #10	ORLY6514A	OB3704A			
05	100	20	2/C #10	IRIY7223B1	OB3705A			
06	100	20	2/C #10	2B9G	OB3706A	MCC2890 SPACE HTR.		
07	100	20	2/C #10		OB3707A	SPARE		
08	100	20	2/C #10		OB3708A			
09	100	20	2/C #10		OB3709A			
10	100	20	2/C #10	1C452	OB3710A	ANALOG ISOLATION CABINET		
11	100	20	2/C #10	1C453 CAB#2	OB3711A	DIGITAL ISOLATION CABINET 273		
12	100	20	2/C #10	1C454	OB3712A	ANALOG ISOLATION CABINET		
13	100	20	2/C #10	2C452	OB3713A	ANALOG ISOLATION CABINET		
14	100	20	2/C #10	2C453 CAB#2	OB3714A	DIGITAL ISOLATION CABINETS 273		
15	100	20	2/C #10	2C454	OB3715A	ANALOG ISOLATION CABINET		
16	100	20	2/C #10		OB3716A	SPARE		
17	100	50	2/C #6		OB3717A			
18	100	50	2/C #6		OB3718A			
19	100	50	2/C #6		OB3719A			
20	100	50	2/C #6		OB3720A			
21	100	20	2/C #10		OB3721A			
22	100	20	2/C #10		OB3722A			
23	100	20	2/C #10		OB3723A			
24	100	20	2/C #10		OB3724A			
25	100	20	2/C #10		OB3725A			
26	100	20	2/C #10		OB3726A			
27	100	20	2/C #10		OB3727A			
28	100	20	2/C #10		OB3728A			

7/21/78	INCORP DCN# 27	BLW	CHD	B.B.	ALL	BY			
10/27/80	INCORP DCN# 31	KLW	CHD	OB	ALL	BY			
11-15-80	ISSUED FOR CONSTRUCTION	KLW	CHD	PRC	CHD	UNGT	UNGT	UNGT	UNGT
NO.	DATE	REVISIONS	BY	CHD	EDIT	GROUP	FILE	CHIEF	ENGR
SCALE	1/8"=1'	DESIGNED		DRAWN		JOB No.	722G		
ORIGIN						DRAWING No.	E-32(1)SH.45	REV.	5

PRC
APERTURE
CARD

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to x-raygraphs.

RIDS

8302030461

