

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

AUX. BLDG.

ELEV. 614'-0" 5.3 1021 PANEL NO. 1021 CHANNEL B

* 1 CONDUCTOR OF THE 3/4 CABLE WILL BE SPARE.

BREAKER NO.	FRAME	TRIP	CABLE SIZE	DESTINATION	SCHEME CABLC NO.	SERVICE DESCRIPTION
01	100	100	2/0-2	1A06	1B02101A	4.1KV SWITCHGEAR CONTROLS
02	100	100	2/0-2	1B10	1B02102A	480V LOAD CENTER CONTROLS
03	100	50	2/0-6	1C44	1B02103A	ESP/ACTUATION CAB/ICM4 CONT. PNL.
04	100	100	2/0-2		1B02104A	SPARE
05	100	90	2/0-6		1B02105A	SPARE
06	100	50	2/0-6		1B02106A	SPARE
07	100	50	2/0-6	1C14	1B02107A	ESP DUPLEX CONT. PNL. 1C14 & 1C24
08	100	20	2/0-10		1B02108A	SPARE
09	100	50	2/0-6		1B02109A	SPARE
10	100	20	2/0-10		1B02110A	SPARE
11	100	20	2/0-10	1C16	1B02111A	MULTI IXY-31118 RELAY CAB
12	100	20	2/0-10	1C39	1B02112A	220V CONDITIONING CAB
13	100	20	2/0-10	1B80	1B02113A	180V PHCC 1B80 PRESS. HTRS.
14	100	20	2/0-6	1M03177A	1B02114A	STEAM GEN. AUX. FEED WTR. VALVE
15	100	20	2/0-6	1M03177B	1B02115A	STEAM GEN. AUX. FEED WTR. VALVE
16	100	20	2/0-6	1M03885B	1B02116A	STEAM GEN. AUX. FEED WTR. VALVE
17	100	20	2/0-10	1C266	1B02117A	AUX. FEED WTR. TURB. 100S
18	100	20	2/0-10	1C112	1B02118A	DIESEL GEN. (1G-2) CONT. PNL.
19	100	20	2/0-10	1C112	1B02119A	DIESEL GEN. (1G-2) CONT. PNL.
20	100	20	2/0-10	1C11	1B02120A	T.G. FR WATER CONT. BOARD

1B02120A DEL. CTR. CRTS. 13120 WERE SPARE

1B02120A INCOMPLETE

1B02120A ISSUED FOR CONSTRUCTION

SCALE: NONE DESIGNED: DRAWN: CHECKED: APPROVED: DATE: BY: FOR: APPR: DATE: BY: FOR: APPR:

ORIGIN: DC DISTRIBUTION PANEL SCHEDULE JOB NO. 7220 DRAWING NO. E-33(Q)SH.7 REV. 7

16X

CERTIFICATE OF MICROFILMING

I certify that the image contained on this frame was made in the normal and regular course of business, on the data stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation.

DATE: 9-14-82 OPERATOR: Pam Smith SUPERVISOR: Sue Crockett

PRC APERTURE CARD

RIDS

8302030474

