

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

NOTE: TERMINATION OF #2/O CABLE WILL BE DONE AS PER NOTE OF DWG. 7220-E33 SH.#17

PANEL NO. 2D22 CHANNEL B

AUX. BLDG. ELEV. 614'-0" COL. H & 7.4

NO.	BREAKER		CABLE SIZE	DESTINATION	SCHEME CABLE NO.	SERVICE DESCRIPTION
	FRAME	TRIP				
01	100	100	3/0#2/0#	2C232	2BD2201B	DIESEL GEN (2G12) CNTRL CAB
02	100	100	2/0#2		2BD2202A	SPARE
03	100	100	2/0#2		2BD2203A	
04	100	70	2/0#2		2BD2204A	
05	100	70	2/0#2		2BD2205A	
06	100	50	2/0#6		2BD2206A	
07	100	50	2/0#6		2BD2207A	
08	100	50	2/0#6		2BD2208A	
09	100	50	2/0#6		2BD2209A	
10	100	50	2/0#6		2BD2210A	
11	100	30	2/0#6	(2J1254)	2BD2211A	CONTROL RM. EMER. LTG.
12	100	30	2/0#6		2BD2212A	SPARE
13	100	30	2/0#6		2BD2213A	
14	100	20	2/0#10	2C21	2BD2214A	POST ACCIDENT MON. PNL
15	100	20	2/0#10	(2C453 CAB#2)	2BD2215A	DIGITAL ISOLATION CAB. 2A3
16	100	20	2/0#10		2BD2216A	SPARE
17	100	20	2/0#10		2BD2217A	
18	100	20	2/0#10		2BD2218A	
19	100	20	2/0#10		2BD2219A	
20	100	20	2/0#10		2BD2220A	

7/3/82 CKT. II WAS SPARE, INC. DCN #7
 8/15/82 CKT. II WAS SPARE
 8-15-82 ISSUED FOR CONSTRUCTION

NO.	DATE	BY	CHK'D	APP'D	FILED	CLIP

SCALE: 1"=10'

DESIGNED: R.E. MASON

DRAWN: ADL

JOB NO. 7220

DRAWING NO. E-33(F) SH. 20

REV. 4

DC DISTRIBUTION PANEL SCHEDULE

16X

CERTIFICATE OF MICROFILMING

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation.

DATE 9-14-82

PRC Smith
CAMERA OPERATOR

Siz Crockett
CONTRACTOR SUPER.

PRC APERTURE CARD

RIDS

8302030482

