


THIS DRAWING AND THE DESIGN IT CARRIES ARE THE PROPERTY OF BECHTEL. THEY ARE HEREBY LOANED AND NOT TO BE REPRODUCED, COPIED, LOANED, REPRODUCED, OR USED IN ANY MANNER WITHOUT THE WRITTEN CONSENT GIVEN BY THE LICENSE TO THE ENGINEER.



10	2-2-73	ADD JUMPER TO TERMINAL BLOCK
0	8-16-77	ISSUED FOR CONSTRUCTION

XFMR	SWGR	BRK NO	SCHEME	KVA	LOCATIONS	LOAD GROUP	SU DESIG
OX21	0A07	152-02	0A0702	750/1000	0A07 OX21	N	0-NGL
OX22	0A08	152-01	0A0801	750/1900	0A08 OX22	N	0-NGL
1X11	1A03	152-05	1A0305	1000/1333	1A03 1X11	N	1-NGL
1X13	1A03	152-06	1A0306	1000/1333	1A03 1X13	N	1-NGL
1X12	1A04	152-05	1A0405	1000/1333	1A04 1X12	N	1-NGL
1X14	1A04	152-06	1A0406	1000/1333	1A04 1X14	N	1-NGL
OX101	0A07	152-05	0A0705	750/1000	0A07 OX101	N	0-NGL
OX19	1A04	152-12	1A0412	1000/1333	1A04 OX19	N	0-NGL
2X13	2A03	152-05	2A0305	1000/1333	2A03 2X13	N	2-NGL
2X11	2A03	152-06	2A0306	1000/1333	2A03 2X11	N	2-NGL
2X14	2A04	152-05	2A0405	1000/1333	2A04 2X14	N	2-NGL
2X12	2A04	152-06	2A0406	1000/1333	2A04 2X12	N	2-NGL
OX102	0A08	152-05	0A0805	750/1000	0A08 OX102	N	0-NGL
OX20	2A04	152-13	2A0413	1000/1333	2A04 OX20	N	0-NGL
OX118	1A04	152-07	1A0407	1000/1333	1A04 OX118	N	0-NGL
1X207	1A03	152-07	1A0307	1000/1333	1A03 1X207	N	1-NGL
2X207	2A03	152-09	2A0309	1000/1333	2A03 2X207	N	2-NGL

- NOTES:**
- CABLES 1A0307A & 2A0309A WERE ORIGINALLY ISSUED FOR CONSTRUCTION ON E-401 SH. 75 AS ONSP017A & C RESPECTIVELY.
 - SHORTING PINS MIGHT HAVE POOR MECH. INTEGRITY. THEREFORE PERMANENT JUMPER IS INSTALLED IN PARALLEL TO THE SHORTING PIN.
- REFERENCES:**
- LOGIC DIAGRAM J-889
V.P. E-205-250, 261, 274, 275, 276, 281, 327, 328, 343, 344, 347, 351, 384, 393

BECHTEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
SCHEMATIC DIAGRAM 4160-480V STATION POWER TRANSFORMER FEEDER BREAKERS		
JOB NO.	ENGINEER NO.	REV.
7229	E-76131 SH. 1	10

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation.

8-10-52 DATE
M. C. 12541 CAMERA OPERATOR
J. C. Thomas CONTRACTOR'S SUPERVISOR OR MANAGER

16X PRC APERTURE CARD

RIDS

8302030513

