

73

This drawing and the design it covers are the property of BECHTEL. They are hereby agreed to by the licensee's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and under the conditions permitted by the license agreement from the licensee to the licensee.

4	Revised	REVISAS INDICATED
3	2/1/79	REVISED AS INDICATED
0	4-2-76	ISSUED FOR CONSTRUCTION

DAMPER NO	CS LOCATION		POSITION SWITCH NO	CRIS SHAN	STATUS LIGHT LOCATIONS	CO <sub>2</sub> FIRE EXTINGUISHER	CO <sub>2</sub> CONTROL STATION NOS.	REFERENCES & NOTES	I-299 MATCH
	CS	LOC							
DMO-8542A	OC20	OC43	OZS-8542A	A	OC13			B-489, SH. 2	
DMO-8542B		OC45	OZS-8542B	A				E-459 SH. 5-6	
DMO-8543A		OC48	OZS-8543A	B		SYSTEM	2C335		
DMO-8543B		OC48	OZS-8543B	B		SYSTEM	1C335		
DMO-8544A		OC49	OZS-8544A	A					
DMO-8544B		OC49	OZS-8544B	A					
DMO-8545A		OC46	OZS-8545A	B		SYSTEM	2C325		
DMO-8545B		OC46	OZS-8545B	B		SYSTEM	1C325		
DMO-8546		OC43	OZS-8546	A					
DMO-8547		OC40	OZS-8547	B					

DWG REVISED NO. 4  
 STARTUP SYSTEMS ≤ 90 DAYS OF TURNOVER, OR AFTER TURNOVER IF AFFECTED BY CHANGES.

System No: OSLN  
 Hardware Change (Yes or No): YES

7220-242

BECHTEL  
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2  
CONSUMERS POWER COMPANY

LOGIC DIAGRAM  
CABLE SPREADING ROOM SUPPLY AND CONTROL  
ROOM EXHAUST DAMPERS

400 No.	REVISION No.	REV.
7220	1-083(0)	4

SH. 2 OF 3

PRC APERTURE CARD

16X

"I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to this contractor for filing, by Bechtel Power Corporation.

6-23-82 DATE  
 M. C. ... CAMERA OPERATOR  
 J. ... CONTRACTOR'S SUP'VR. OR MANAGER

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

RIDS

8302040242

