



REV	DESCRIPTION	BY	CHK	APPROVAL	DATE

**RCP PUMP LOAD PATH NOTES**  
 RCP PLUGS STORE ON TOP OF HEAD PLUGS, ON TOP OF OTHER RCP PLUGS, OR ON TOP OF PRESSURIZER  
 RCP MOTORS STORE ON TOP OF OTHER RCP PLUGS (WHEN IN PLACE) ON SEAL TABLE PLUG OR BETWEEN STEAM GEN. "C" AND PRESSURIZER  
 POSITION RCP INTERNALS AND CRADLE OVER RCP "A", "B" OR "C" TO SUIT CONDITIONS

- NOTES:**
- LOADS AND COMPONENTS NOT HAVING SPECIFIC LOAD PATHS SHOWN CAN BE MOVED ANYWHERE ON OPERATING FLOOR EXCEPT OVER REACTOR VESSEL WHEN THE MISSILE SHIELD HAS BEEN REMOVED FOR MAINT. OR REFUELING.
  - CRANE OPERATOR SHOULD AVOID HANDLING LOADS OVER MANIPULATOR CRANE. POSITION OF THE MANIPULATOR CRANE WILL VARY.
  - HEAVY LOADS MAY BE HANDLED ANYWHERE IN SHADED AREA.

TERA  
 APERTURE  
 CARD

CAROLINA POWER & LIGHT COMPANY					
NUCLEAR PLANT ENGINEERING DEPARTMENT - RALEIGH, N. C.					
PLANT: ROBINSON STEAM ELECTRIC PLANT					
TITLE: CONTROL OF HEAVY LOADS					
SAFE LOAD PATHS					
REACTOR CONTAINMENT BUILDING					
DRAWN BY	CHECK BY	ENGR.	APPROVED BY	SCALE	SHEET OF
SKM	J.S.G.	J.S.G.	J.S.G.	7-2-61	NO. 61022-M-002A

DUNCAN-PARNELL, INC., RALEIGH 181

8108170290

RIDS

8108170290

