



INSTRUMENT LOCATION DRAWING GENERAL NOTES.

1. INSTRUMENT BACK/MULTIPLE INSTRUMENT MOUNTING SUPPORTS ARE IDENTIFIED AS FOLLOWS:
 UNIT NUMBER - ASSIGNED NUMBER
 2. SINGLE INSTRUMENT MOUNTING SUPPORTS ARE NOT ASSIGNED NUMBERS.
3. REFER TO THE INSTRUMENT INSTALLATION JOURNAL FOR ADDITIONAL INSTALLATION INFORMATION.
4. SINGLE INSTRUMENTS SHALL BE MOUNTED 4'-6" TO 5' ABOVE THE FINISHED FLOOR OR PLATFORM LEVEL. THE MOUNTING HEIGHT IS NOT APPLICABLE TO THE INSTRUMENT (EXCEPT WHERE NOTED) WHICH MAY BE MOUNTED AS LOW AS 4'-0" ABOVE THE FINISHED FLOOR OR PLATFORM TO MEET THE INSTRUMENT MANUFACTURER'S AND RELATED DRAWING DETAILS.
5. ALL INSTRUMENTS SHALL BE TO THE INSTRUMENT NAME OR INSTRUMENT MOUNTING SUPPORT CENTERLINE, UNLESS OTHERWISE NOTED.
6. FIELD-MOUNTED INSTRUMENT BACKS OR INSTRUMENT MOUNTING SUPPORTS SHALL BE DIMENSIONED TO THE 75% STRIKELINE. INSTRUMENTS MOUNTED ON THE 50% STRIKELINE OR AT A MOUNTING HEIGHT OF 40 INCHES OR LESS SHALL BE DIMENSIONED TO THE 50% STRIKELINE. THIS DIMENSION IS ESTABLISHED BY THE INSTRUMENT MANUFACTURER'S AND RELATED DRAWING DETAILS.
7. THE "HOLE" WHICH WERE ON PIPING PLANS HAVE BEEN REPORTED FOR CLARITY.
8. AREA RADIATION MONITORS ARE TO BE MOUNTED BETWEEN 8 AND 6' ABOVE THE FINISHED FLOOR OR PLATFORM.

LEGEND

- SELF-CONTAINED RADIATION MONITOR DEVICE ELECTRICAL CONNECTIONS ONLY.
- SELF-CONTAINED RADIATION MONITOR DEVICE.

INSTRUMENT LOCATION AND TAP LIST

1. TAP LOCATIONS FOR THESE INSTRUMENTS ARE SHOWN ON:
2. SEE DWG 7220-J-3134(Q) FOR TAP LOCATION.
3. DELETED
4. THESE ARE TAP LOCATIONS ONLY. FOR INSTRUMENT LOCATION SEE:
 - a. J-3102 (Q)
 - b. J-3103 (Q)

NO.	REVISION	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1	ISSUED FOR CONSTRUCTION	7/22/68	J. J. [unclear]	[unclear]	[unclear]	[unclear]
2	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
3	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
4	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
5	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
6	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
7	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
8	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
9	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
10	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
11	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]
12	REVISED AS INDICATED	8/1/68	[unclear]	[unclear]	[unclear]	[unclear]

CERTIFICATE OF ACCURACY
 I certify that the data contained on this drawing was made in the normal and regular course of business, on the data stated below and that it is an accurate reproduction of the same as submitted to the contractor for filing, by [unclear] Mechanical Power Corporation.

PRC APERTURE CARD

THIS DRAWING REPRODUCED FROM 7220-M-3101 REV. 0. USE THIS DRAWING FOR INSTRUMENT LOCATION ONLY. FOR ALL OTHER DATA REFER TO APPLICABLE DRAWINGS.

BECHTEL AND ASSOCIATES	
MIDLAND PLANT UNITS 1&2 CONSIDERS POWER CONSTAT	
INSTRUMENT LOCATION DRAWING AREA 1 PLAN OF EL 568'-0"	
7220	J-3101 (Q)
11	

RID's

8302040313

