



- NOTES
- OPERATED FROM STANDBY SHUTDOWN FACILITY.
  - REROUTED TO BE LOCATED IN STANDBY SHUTDOWN FACILITY.
  - REFER TO AS-BUILT INFORMATION CERTIFICATION SHEET FOR EXCEPTIONS.
  - PUMP SECTION CONNECTION IS NOT TO BE ABOVE ELEVATION 720' MSL.
  - VALVES & CONTROLS ADDED BY CONSTRUCTION FOR FLUSH & HYDRO.
  - VALVE AND GYFT - SEATED DISC.

DESIGN PARAMETERS

NO	PRESSURE	TEMPERATURE	CLASS	MATERIAL
11	27.75 PSIG	180°F	B	304
61	27.75 PSIG	180°F	B	304
68	20 PSIG	250°F	B	304
69	30 PSIG	250°F	B	304
70	27.75 PSIG	250°F	B	304

TERA APERTURE CARD

NOTE 4  
AS BUILT  
DATE 4-3-78

6. AUTHORIZED PRESSURE BOUNDARY TESTS - Ref. 2 (Conf. 1-21-8)  
 7. CLEANED FOR PRESSURE BOUNDARY TESTING - Ref. 2 (Conf. 1-21-8)

SYSTEM CHANGE ORDER NUMBER 11554-1.3

REVISIONS FOR AS-BUILT: YES  NO

NO.	DESCRIPTION	DATE	BY	CHKD.
1	AS-BUILT	4/3/78	J. J. [Signature]	[Signature]

Q.A. CONDITION 2
Q.A. CONDITION 1
DUKE POWER COMPANY
MEDLINE NUCLEAR DIVISION UNIT 1
FLOW DIAGRAM OF
STANDBY SHUTDOWN FACILITY
SYSTEM (SWS)

DESIGNED BY	DATE	DESIGNED BY	DATE	DESIGNED BY	DATE
CHECKED BY	DATE	CHECKED BY	DATE	CHECKED BY	DATE
APPROVED BY	DATE	APPROVED BY	DATE	APPROVED BY	DATE

DWG. NO. MC-1554-1.3

8.5"

11"

17"

RIDS

8108240373

