



- (1) TRIP FUEL POOL CLG PUMP 1B
- (2) TRIP SHUTDOWN SERVICE WTR. PUMP 1B
- (3) TRIP RHR PUMP 1B
- (4) TRIP DRYWELL CHILLER 1B
- (5) TRIP RHR PUMP 1C
- (6) TRIP DG FEED BKR. 252-DG1KB
- (7) INTLK CLOSE DG FEED BKR. 252-DG1KB
- (8) INTLK CLOSE RES. FEED BKR. 252-221B1
- (9) DEACTIVATES RHR-221B1

DRAWING RELEASE RECORD					DRAWING RELEASE RECORD										
REV.	DATE	RELT.	PREPARED	REVIEWED	APPROVED	PURPOSE	FILM	REV.	DATE	RELT.	PREPARED	REVIEWED	APPROVED	PURPOSE	FILM
								A	6-24-80		Forshaw	W. J. P.	W. J. P.	FOR CONSTRUCTION SPEC K-2999	



NUCLEAR SAFETY RELATED EQUIPMENT IS SHOWN ON THIS DRAWING
 (FOR SAFETY CLASSIFICATION SEE EQUIPMENT, VALVE, OR INSTRUMENT LISTS.)

SCALE: NONE
 PROJECT NUMBER: 453C-00
 LOGIC BLOCK DIAGRAM
 4.16KV BUS 1B1 MAIN FEED BREAKER
 252-201B1
 CLINTON POWER STATION, UNIT 1
 ILLINOIS POWER COMPANY
 CLINTON, ILLINOIS

SARGENT & LUNDY
 DRAWING NO. E02-1AP02
 REV. A
 SHEET 005 OF 01
 8109010585

Rios

8109010585

