



This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and under special conditions permitted by any written consent given by the lender to the borrower.

REV.	DATE	BY	CHKD.	DESCRIPTION
1	11/11/72	W.A.H.	J.R.	ISSUED FOR CONSTRUCTION
2	11/11/72	W.A.H.	J.R.	REVISED BY AUX. RELAY CONTACTS
3	11/11/72	W.A.H.	J.R.	REVISED BY AUX. RELAY CONTACTS

DEVICE TABLE:
 IFSL-5323: LOW FLOW SWITCH
 62-1/TDE: TIME DELAY DE-ENERGIZED RELAY (AGASTAT 7022AE)
 62/TDE: TIME DELAY ENERGIZE RELAY (AGASTAT 7014AC)
 FJ: FUSE (AMP TRAP AGY2-2)
 3X: AUX. RELAY (G.E. TYPE HGA)

AIR ROOM SUPPLY A/H UNIT IVM-57
 SCHEME INB5724
 SU DESIG 1-GTB

PRG
 APERTURE
 CARD

NOTES:
 1. FOR LOW TEMP ALARM SEE SH-10A

REFERENCE
 LOGIC DIAGRAM J-843
 VP 7220-M304-10, VP 7220-M340-16, 78
 VP 7220-M160-66
 E 99 TYPE A-6

BECHTEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
SCHEMATIC DIAGRAM REACTOR CONTAINMENT BUILDING H & V SYSTEMS		
JOB No.	DRAWING No.	REV.
7220	E-440 (3) SH 17	5

KWS

8302090149

