



30X

- NOTES:**
1. ASTRERIZED WYE STRAINERS ARE PROVIDED BY DEMINERALIZER VEH OR CR NO. 2850-NA-60.
 2. SERVICE AIR TO BE SUPPLIED TO THE VESSEL HEADS. CONNECTED SERVICE PLUMBING TO BE CLOSED EXCEPT WHEN AIR IS REQUIRED.
 3. LINES F-ONCD-008 AND 010 HAVE BEEN PROVIDED TO ENABLE OPERATOR TO DETECT WATER IN THE HEAT EXCHANGER AND SHOULD BE LOCATED IN A READILY ACCESSIBLE LOCATION.

NO.	DATE	REVISION	BY	CHKD.
1	10/1/68	ISSUED FOR CONSTRUCTION
2	10/1/68
3	10/1/68
4	10/1/68
5	10/1/68
6	10/1/68
7	10/1/68
8	10/1/68
9	10/1/68
10	10/1/68

BECHTEL
 AND ASSOCIATES
 BERKELEY, CALIFORNIA
 ENGINEERS

PHILAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY

PIPING AND INSTRUMENT DIAGRAM
 BORON RECOVERY UNIT 1 & 2

JOB NO.	PACKAGE NO.	SHEET NO.
7220	M-408 SH.20	3

PRO APERTURE CARD

17"
 8.5"
 11"
 8.5"
 17"

17"
 8.5"
 11"
 8.5"
 17"

RIDS

8302090486

