



POOR ORIGINAL

PRC APERTURE CARD

- NOTES:
1. ALL VALVES ARE ASSUMED TO BE LOGIC CONTROLLED FROM CONTROL ROOM UNLESS OTHERWISE NOTED.
 2. LABEL INDICATORS (M-4438 & M-4439) ARE TO BE LOCATED NEAR PIPES.
 3. LOCATIONS OF LINE PIPES, PATTERNS TO ALLOW VISUAL PLACEMENT OF TRAIL.
 4. PIPING IS TO BE DONE IN ACCORDANCE WITH LINE.
 5. ALL DEVICES REQUIRING INSTRUMENT AIR ARE CONNECTED TO VENDOR MANIFOLDS. ALL MANIFOLDS ARE INTERCONNECTED SUCH THAT A SINGLE AIR SUPPLY WILL SERVICE ALL THE DEVICES SHOWN ON P 610 M-4428 & M-4438.

NO.	DESCRIPTION	DATE	BY
1	AS SHOWN		
2	REVISION		
3	REVISION		
4	REVISION		
5	REVISION		
6	REVISION		
7	REVISION		
8	REVISION		
9	REVISION		
10	REVISION		

BECHTEL		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
PIPING AND INSTRUMENT DIAGRAM CONDENSATE DEMINERALIZER REGENERATION UNIT 2		
JOB NO.	DRAWING NO.	REV.
7720	M-4438	5

30X

RIDS

8302100497

