



NOTES:
 1. CONTROLS ARE MOUNTED ON VENDOR SUPPLIED LOCAL CONTROL PANELS
 IC10, IC101, IC106, AND IC106.
 2. HYDRAZINE SHOULD NOT BE DRAINED TO TURBINE BLDG. NEUTRALIZATION SUMP. IT SHOULD BE DRAINED TO TURBINE BLDG. SUMP.

PRO
 APERTURE
 CARD

NONE		2-445	M. JONES
BECHTEL			
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY			
PIPING AND INSTRUMENT DIAGRAM FEEDWATER CHEMICAL ADDITION UNIT-1			
JOB NO.	DRAWING NO.	REV.	
7226	M-414 A	3	

30X

17" 8.5" 11" 9.8" 11" 9.8" 17" 8.5" 11" 17"

RIDS

8302100498

