


- NOTES**
1. THE TRAVELING SCREENS ARE GROUPED TO SERVICE THE CIRCULATING WATER PUMPS AS FOLLOWS:

TRAVELING SCREENS	CIRCULATING WATER PUMPS
1F-108A, B	1P-001A
1F-108C, D	1P-001B
2F-108A, B, C	2P-001A
2F-108D, E, F	2P-001B
 2. THE SPACE HEATER WIPING IS SHOWN ON VENDOR PRINTS 2807-M-00-1-100(1), AND (2), AND (3).
 3. THERE ARE A TOTAL OF 50 OTHER HEATERS EVENLY SPACED ALONG THE ENTIRE LENGTH OF THE TRIMMER AND ITS EXTENSION. REFER TO VENDOR PRINTS 2807-M-00-1-100 AND 2807-M-00-1-000 FOR WIPING CONNECTIONS.
 4. ROOT VALVE 270 TO BE OPERATED DURING WATER OPERATION OF SYSTEM.



PRC APERTURE CARD

SEE TYP DETAIL (M-6)
 PLANNED FOR FUTURE SCREEN REFUSE THROUGH CONNECTION

REVISED AS INDICATED

NO.	DATE	BY	CHKD
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			

<p>BECHTEL 4800 ARDEN, MICHIGAN</p>			
<p>MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY</p>			
<p>PIPING AND INSTRUMENT DIAGRAM CIRCULATING WATER (TRAVELING SCREEN SYSTEM UNITS 1 & 2)</p>			
<p>JOB NO. 7220</p>	<p>DRAWING NO. M-446C</p>	<p>REV. 3</p>	<p>DATE 11/24/61</p>

8.5"
11"
17"

8.5"
11"
17"

RIDS

8302100504

