



- NOTES**
1. DS-01 HAS A CONSTANT HIGH AIR INPUT PRESSURE. IT IS TO BE KEPT TO ALL PNEUMATIC INSTRUMENTATION IN SYSTEM.
 2. DS-01 IS A PNEUMATIC SELECTOR WHICH SELECTS ALL INPUT SIGNALS AND PASSES ONLY THE HIGHEST AND LOWEST AIR PRESSURE SIGNALS AS OUTPUTS FOR RELAYING OF THE AIR TO THE CONTROL AIR INSTRUMENTS.
 3. SYMBOL REPRESENTS AS FLEXIBLE CONNECTION.
 4. REPRESENTS AS FLEXIBLE CONNECTION.
 5. IS A HIGH SET BACK TIME SWITCH FOR AUTOMATIC AIR HANDLER SHUT DOWN AND START UP.

PRC
APERTURE
CARD

30X

DATE	BY	REVISION

REVISION	DATE	BY	REVISION	DATE	BY

BECHTEL
 MIDLAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY
 PIPING AND INSTRUMENT DIAGRAM
 HEATING VENTILATING & AIR CONDITIONING
 OFFICE & SERVICE BUILDING

JOB NO.	DRAWING NO.	REV.
7220	M-467 SH. 3	3

11
11
8.5"
8.5"
11"
8.5"
11"
17"

SIZE E
11
11
8.5"
8.5"
11"
8.5"
11"
17"

RIDS

8302/40/62

