



30X

DATE: 10/26/64

BY: [Signature]

REVISIONS:

NO.	DESCRIPTION	DATE
1	ISSUED FOR CONSTRUCTION THIS DRAWING IS TO BE SUPERSEDED BY THE LATEST REVISIONS. REVISED AS INDICATED.	10/26/64

- NOTES:
1. OVERSIZED LINES DRAINAGE INTO TURBINE BLDG. NEUTRALIZING & CLEAN WASTE SUMP'S SHOWN ON PROCESS DRAWINGS DWGS. 7220-M-227 & 7220-M-233 & PIPING DIAGRAM M-240 & M-272.
 2. THE LEVEL SWITCH HAS A MECHANICAL ALTERNATOR TO ALTERNATE OPERATION OF THE PUMPS ON HIGH LEVEL & THE PUMPS TO RUN ON HIGH LEVEL.
 3. THE LEVEL SWITCH ALARMS ON HIGH LEVEL FOR MANUAL START OF THE PUMPS & STOPS THE PUMPS ON LOW LEVEL.
 4. OVERSIZED LINES DRAINAGE INTO THE EVAPORATOR BUILDING NEUTRALIZATION SUMP'S ARE SHOWN ON PROCESS DRAWINGS DWGS. M-245 AND PIPING DIAGRAM M-272.
 5. THE SUMP'S HAVE OPEN TOPS TO COLLECT FLOOR DRAINAGE.
 6. PROVIDE CLEARANCE FOR PUMP REMOVAL & SERVICE AS INDICATED.

BECHTEL
400 15TH STREET, BERKELEY, CALIF. 94710

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

PIPING & INSTRUMENT DIAGRAM
CHEMICAL & OILY WASTE

7220	M-470 SH2B	6
------	------------	---

PRC
APERTURE
CARD

This drawing and the design it covers are the property of BECHTEL. They are made based on the information supplied to BECHTEL by the customer. BECHTEL, its agents, and its subcontractors are not responsible for any errors or omissions in this drawing or for any consequences that may result therefrom.

RIDS

8302140182

