
[illegible]

REF: CONTROL ROOM ARRGT, 12210-E2-27A.

- NOTES:
- 1. FOR EQUIPMENT LIST SEE 1210.0-EXH-A661122
- 2. FOR NAMEPLATE ENGRAVING LIST, SEE 1210.0-EXH-A661124
- 3. PROVIDE REAR ACCESS UNLOADED DOORS AND VENTILATED PANEL TOPS FOR NATURAL CONVECTION COOLING OF COMPONENTS.
- 4. DOTTED CIRCLES BELOW PANELS INDICATE ITEMS NOT INSIDE THAT CABINET BAY.
- 5. UNOCCUPIED PANEL AREA (TYPICAL AS SHOWN) THAT CAN BE USED FOR ADDITIONAL COMPONENTS. THIS AREA CAN BE USED FOR CLEAR OF WIRING, STRAPPERS, ETC. ROUTING OF WIRING TO BE SUCH THAT ADDITION OF COMPONENTS CAN BE DONE WITH MINIMUM OF REWORK.
- 6. SCALE: 1/2" = 1'-0"

TERA
APERTURE
CARD

NUCLEAR SAFETY, RELATED
QA CAT I, II

OUTLINE	H13-P651
BOP AUX RELAY PANEL - DIV I	
RIVER BEND STATION - UNIT 1	
GULF STATES UTILITIES COMPANY	
STONE & WEBSTER ENGINEERING CORPORATION	
	12210-ESK-4CES22

SEPIA COPY

22"

KIDS

8109230607

