



- NOTES**
1. FOR SYMBOL & ABBREVIATION LISTS SEE DWG. G-4023.
  2. AIR FLOW DIAGRAMS ARE SCHEMATIC AND ARE NOT INTENDED TO REPRODUCE THE ACTUAL SEQUENCE OF DUCT CONNECTIONS AS THEY OCCUR ON THE PHYSICAL DRAWINGS.
  3. FOR LOCATION OF R-ANGING DAMPERS REFER TO THE PHYSICAL DRAWINGS.
  4. THE SUPPLY & RETURN TOTALS (CFM) INCLUDE TRAIN A & B CONSTANT CFM, MAXIMUM CFM FOR THE OPERATING TRAIN AND THE MINIMUM CFM FOR THE TRAIN NOT OPERATING.
  5. HVAC VENT STACKS TO BE SIZED FOR NORMAL PLANT OPERATION.
  6. AIR FLOW QUANTITIES SHOWN ARE BASED ON A DENSITY OF 0.075 LB/FT<sup>3</sup> OCCURRING AT THE STANDARD CONDITION OF DRY AIR AT 70°F AND 29.92 Hg BAROMETRIC PRESSURE.
  7. EH INDICATES ELECTRO-HYDRAULIC DAMPER OPERATOR.
  8. FOR INSTRUMENTATION SEE NOTES G-418 ON DWG. G-4001(E-9).

**REFERENCE DRAWINGS**

LIST OF DRAWINGS	G-1005
HVAC-AIR FLOW DIAGRAM	G-4002
HVAC-AIR FLOW DIAGRAM	G-4003
HVAC-AIR FLOW DIAGRAM	G-4004
HVAC-AIR FLOW DIAGRAM	G-4001
HVAC-AIR FLOW DIAGRAM	G-4011
HVAC-SYMBOLS & ABBREVIATIONS	G-4023

**WPPSS QUALITY CLASS I & II**

DWG. CONTAINS:  
 CONTRACT No. 212  
 CONTRACT No.

**NUCLEAR SAFETY RELATED**

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECTS NO. 385  
 1968-1900 KW INSTALLATION  
 1932-1900 KW INSTALLATION  
 HVAC-AIR FLOW DIAGRAM  
 ELECTRICAL & BATTERY ROOMS

EBASCO SERVICES INCORPORATED

DATE: 7-7-77  
 WPPSS-2400  
 G-4008

ELECTRICAL & BATTERY ROOMS

RIDS

8302250464

