



NOTES

- FOR SYMBOL & ABBREVIATION LISTS SEE DWG. G-4023.
- AIR FLOW DIAGRAMS ARE SCHEMATIC AND ARE NOT INTENDED TO REPRODUCE THE ACTUAL SEQUENCE OF DUCT CONNECTIONS AS THEY OCCUR IN THE PHYSICAL DRAWINGS.
- FOR LOCATION OF BALANCING DAMPERS REFER TO THE PHYSICAL DRAWINGS.
- AIR FLOW QUANTITIES SHOWN ARE BASED ON A DENSITY OF 0.075 LB/FT³ OCCURRING AT THE STANDARD CONDITION OF DRY AIR AT 70°F & 29.92" Hg BAROMETRIC PRESSURE.
- FOR INSTRUMENTATION SEE NOTES G-140 ON DWG. G-1001 (E-17).

REFERENCE DRAWINGS

LIST OF DRAWINGS

HVAC AIR FLOW DIAGRAM	G-1005
FAB-COMPOSITE	G-4001
HVAC AIR FLOW DIAGRAM	G-4005
HVAC-SYMBOLS & ABBREVIATIONS	G-4025

WPPSS QUALITY CLASS II

CONTRACT NO.	252
CONTRACT NO.	

PRC APERTURE CAR

WASHINGTON STATE DEPARTMENT OF TRANSPORTATION

NO.	DATE	DESCRIPTION	BY	CHKD.
1	05/18/82	ISSUED FOR PERMITS		
2	05/18/82	ISSUED FOR PERMITS		

6844CO
SET 05/18/82
CONSTRUCTION SITE

RIDS

8302250471

