



VALVE & LINE NOS CH WTR EXP TANK A-SA

LEVEL GAGE A	LEVEL GAGE B	LEVEL GAGE C
1 SEC-VE335A	SEC-VE337A	SEC-VE339A
2 SEC-VE332A	SEC-VE334A	SEC-VE340A
3 SEC-VE342A	SEC-VE344A	SEC-VE346A
4 SEC-VE348A	SEC-VE350A	SEC-VE352A
5 SEC-VE358A	SEC-VE360A	SEC-VE362A
6 SEC-VE368A	SEC-VE370A	SEC-VE372A

VALVE & LINE NOS CH WTR EXP TANK B-SB

LEVEL GAGE A	LEVEL GAGE B	LEVEL GAGE C
1 SEC-VE342SB	SEC-VE344SB	SEC-VE346SB
2 SEC-VE348SB	SEC-VE350SB	SEC-VE352SB
3 SEC-VE358SB	SEC-VE360SB	SEC-VE362SB
4 SEC-VE368SB	SEC-VE370SB	SEC-VE372SB
5 SEC-VE378SB	SEC-VE380SB	SEC-VE382SB
6 SEC-VE388SB	SEC-VE390SB	SEC-VE392SB

NOTES

1. COMPANION FLANGES FOR WC-1A-SA & WC-1B-SB COOLER & CONDENSER. NOTICES ARE SUPPLIED BY CHILLER MFG.
2. PRESSURE DIFFERENTIAL SWITCHES ARE VENDOR SUPPLIED, AND ARE INTEGRALLY MOUNTED ON THE CHILLER.
3. FOR PRESSURE VENT & DRAIN DETAIL SEE DWG G-4015 & G-4017.
4. AFTER INITIAL FILL VALVES WILL BE LOCKED CLOSED & SIGHT GLASS DRAINED. THEREAFTER OPENED ONLY WITH PRIOR AUTHORIZED APPROVAL.

REFERENCE DRAWINGS

HVAC-CHILLED WATER FLOW DIAGRAMS:

- REACTOR BLDG. 3240-G-4013
- REACTOR AUXILIARY BLDG. 3240-G-4016
- RAB NON-NUCLEAR SAFETY EQUIP. 3240-G-4015

SYMBOL LIST

- LINE LIST 3240-B-1060
- VALVE LIST 3240-A-1006
- AUX FEED WATER SYSTEM 3240-G-1078
- COMPONENT COOLING WATER 3240-G-1061
- STATION INSTRUMENT AIR 3240-G-1064
- MAKE-UP WATER & DRAINS SCHEMATIC 3240-G-4975

WPPSS QUALITY CLASS I II

DWG. CONTAINS:

CONTRACT No.	251
CONTRACT No.	
CONTRACT No.	232

NUCLEAR SAFETY RELATED

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

NUCLEAR PROJECTS NO. 305

100-1000 MW INSTALLATION

1000-000 MW INSTALLATION

HVAC

CHILLED WATER FLOW DIAGRAM

EQUIPMENT & HEADERS

ES&BCO SERVICES INCORPORATED

DATE 9-6-77

WPPSS 3240

G-4014

RIDS

8303010149

