



- NOTES:
1. CONCRETE AND FLOORING TYPE SHALL BE INDICATED BY REFERENCE TO SPECIFICATIONS AND A-3 CONTRACT SPECIFICATIONS AND DRAWINGS.
 2. SLEEVE MATERIAL TYPE ASTM A36 OR A572 GR. 50.
 3. SLEEVES, ANCHORS AND SEALING COMPOUND AND PENETRATION TYPE SHALL BE AS SHOWN BY CONTRACT NO. 228, 229 & 230.
 4. SEE A-3 NOTES ON DWG. G-3221-G1, G-3222-G1, G-3223-G1, G-3224-G1 & G-3225-G1.
 5. METHOD AND MATERIAL FOR RADIATION ANALYSIS FIRE PROTECTION SHALL CONFORM TO SPECIFICATION 3240-489.
 6. SEE INSTRUMENT INSTALLATION DETAIL DWG. G-3226-G1 TO DETERMINE TUBING SIZE, MATERIAL AND TYPE OF INSTALLATION.
 7. SEE DWG. G-6000-G1 FOR DETAILS OF PENETRATION SEALING AND PROTECTIVE COATING.
 8. 1/2" DIA. GMP HOOKS SHALL BE USED UNLESS TYPE HAS BEEN SPECIFIED IN TO ACTION A-108.
 9. FOR CONCRETE PLACEMENTS THAT REQUIRE G-DECKING, CONTRACTOR SHALL HAVE THE OPTION TO PLACE PIPE SLEEVES ON THE TOP OF G-DECKING WITH A 7" PROJECTION OR FLUSH WITH THE BOTTOM OF THE G-DECKING WITH A 3" PROJECTION. CUT G-DECKING AROUND PIPE SLEEVE PLATE AND CAST CONCRETE AS NECESSARY TO EXPOSE THE END OF PIPE SLEEVE. SLEEVES PLACED ON TOP OF THE G-DECKING SHALL BE INSTALLED WITH A SLOTTED (NOT SLOTTED FROM CAP PLATE) PROVIDED BELOW THE SLEEVE PLATE SUCH THAT CONCRETE CHECKERS WILL NOT BE REQUIRED TO BRIDGE OVER PLATE. CHECKERS, IF REQUIRED, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.
 10. FOR CONCRETE PLACEMENTS THAT REQUIRE G-DECKING, CONTRACTOR SHALL HAVE THE OPTION TO PLACE PIPE SLEEVES ON THE TOP OF G-DECKING WITH A 7" PROJECTION OR FLUSH WITH THE BOTTOM OF THE G-DECKING WITH A 3" PROJECTION. CUT G-DECKING AROUND PIPE SLEEVE PLATE AND CAST CONCRETE AS NECESSARY TO EXPOSE THE END OF PIPE SLEEVE. SLEEVES PLACED ON TOP OF THE G-DECKING SHALL BE INSTALLED WITH A SLOTTED (NOT SLOTTED FROM CAP PLATE) PROVIDED BELOW THE SLEEVE PLATE SUCH THAT CONCRETE CHECKERS WILL NOT BE REQUIRED TO BRIDGE OVER PLATE. CHECKERS, IF REQUIRED, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

ANCHORS SHALL BE INSTALLED AS SHOWN IN DETAIL DWG. G-3226-G1.

CONCRETE SHALL BE CAST IN PLACE AS SHOWN IN DETAIL DWG. G-3226-G1.

PIPE SLEEVES SHALL BE INSTALLED AS SHOWN IN DETAIL DWG. G-3226-G1.

PRC APERTURE CARD

- REFERENCE DWGS:
1. INSTRUMENT LOCATION AREA DWGS. G-5111 THRU G-5120, G-5121 THRU G-5130, G-5131 THRU G-5140, G-5141 THRU G-5150, G-5151 THRU G-5160, G-5161 THRU G-5170.
 2. A-3 CONCRETE PENETRATION DWGS. G-3221 THRU G-3225, G-3226 THRU G-3230, G-3231 THRU G-3235, G-3236 THRU G-3240, G-3241 THRU G-3245, G-3246 THRU G-3250.

DATE: APR 1, 1977

BY: [Signature]

PROJECT: [Illegible]

SCALE: [Illegible]

NO. [Illegible]

11

11

11

11

11

11

11

11

11

11

11

11

RIDS

8303010/72

