



INST. RACK RA-29
ZONE (D-3)

RA29-2155	PI-WM 6209, POS-WM 6209 (H.P.)
RA29-2156	PI-WM 6210, POS-WM 6209 (L.P.)
RA29-2157	PI-WM 6207, POS-WM 6207 (H.P.)
RA29-2158	PI-WM 6208, POS-WM 6207 (L.P.)
RA29-2159	PI-WM 6206 (H.P.)
RA29-2160	PI-WM 6206 (L.P.)

INST. RACK RA-30
ZONE (D-2)

RA30-2159	PI-WM 6428, POS-WM 6428 (H.P.)
RA30-2158	PI-WM 6429, POS-WM 6428 (L.P.)
RA30-2157	PI-WM 6430, POS-WM 6430 (H.P.)
RA30-2156	PI-WM 6431, POS-WM 6433 (L.P.)

ELECTRONIC HOT CT-WM 6429

INST. RACK RA-31
ZONE (D-1)

RA31-2160	PI-WM 6117, POS-WM 6117 (H.P.)
RA31-2159	PI-WM 6118, POS-WM 6117 (L.P.)
RA31-2158	PI-WM 6119, POS-WM 6119 (H.P.)
RA31-2157	PI-WM 6118, POS-WM 6119 (L.P.)

ELECTRONIC HOT CT-WM 6119

INST. RACK RA-65
ZONE (H-1)

RA65-2165	LT-26 (H.P.), LT-26 (L.P.)
RA65-2164	LT-26 (L.P.), LT-27 (L.P.)
RA65-2163	LT-27
RA65-2162	PT-220
RA65-2161	PT-225

NOTES:
1. FOR GENERAL NOTES, SYMBOLS & REFERENCES, SEE DWG. NO. D-8087
2. ALL OPERATED VALVES IN 4" & 6" DIA. PIPING TO BE CHECKED BY FIELD CONTRACTOR TO VERIFY INST. ARE AND ASSOCIATED TAGS & THREE ALING.
3. SEISMIC CLAS. I INSTRUMENTS AND SENSING COILS SHALL NOT BE SUPPORTED OFF CONCRETE BLOCK WALLS.

PLAN EL. 362.50



FOR ORIGINAL SENT TO ESSE WPPS QUALITY CLASS

PRO APERTURE CARD

INCORPORATED DATE: 11/15/74
REVISION: (4-7) NOTES
APPROVED: (NO) VA. 12, (P) VA. 12
INCORPORATED BY: BSM/SLA
REVISION: (4-7) 11/15/74

DATE: 11/15/74

PROJECT NO. 227

DATE: 11/15/74

SCALE: AS SHOWN

APPROVED: [Signature]

DATE: 11/15/74

RIDS

8303030258

