



NOTE:  
1. FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH. 2111

LIMIT SW DEVELOPMENT			
EBASCO S. MBCL	CONT.	VALVE OPNG. %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT CLOSED \* THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-3240	
DIV. CONTROL DR. RK		APPROVED		D-6001	
CH. V. ALKSNINIS		DATE JUNE 8, 1978		SHEET 2853	
REV.	DATE	BY	APPROVED		
1	12-23-81	EM			
2	5-23-80	UL			



RIDS

8303030320

