



NOTE:
1. FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH.2112

EBASCO SYMBOL	LIMIT SW DEVELOPMENT		CWD SH.
	CONT.	VALVE OPNG. %	
bo	1-2	0	*
ac	3-4	100	*
bo	5-6	0	*
ac	7-8	100	*
ao	9-10	0	*
bc	11-12	100	*
ao	13-14	0	*
bc	15-16	100	*
a %	17-18	0	*
b %	19-20	100	*
a %	21-22	0	*
b %	23-24	100	*
a %	25-26	0	*
b %	27-28	100	*
a %	29-30	0	*
b %	31-32	100	*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-48	OPENS ON OVERLOAD ON OPEN STROKE	*

--- CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS 1

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. RK CH. VALMSINIS DATE JUNE 8, 1978			WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM ECCS EQUIP AREA - ENH VA 2FV-11373B		WPPSS-3240 D-6001 SHEET 2960	
REV.	DATE	BY	APPROVED			
1	12-23-81	EV	LN			

RIDS

8303030331

