



NOTE:
1. FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH. 2112

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	
		0	100
bo	1-2		*
oc	3-4		*
bc	5-6		*
ac	7-8		*
oo	9-10		*
bc	11-12		*
oo	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R.K. CH. V. ALKSNINIS DATE JUNE 8, 1978	APPROVED <i>D.P. Price</i> DATE	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3-3-5 CONTROL WIRING DIAGRAM ECCS MECH. PENE AREA, B EXH VA 2FV-B1405B	WPPS-9240 D-6001 SHEET 2661
--	--	---	---------------------------------------	---	---

RIDS

8303030333

