



NOTE:
1. FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH. 2112

| LIMIT SW DEVELOPMENT | | | | |
|----------------------|-------|-----------------------------------|-----|---------|
| EBASCO SYMBOL | CONT. | VALVE OPNG. % | | CWD SH. |
| | | 0 | 100 | |
| bo | 1-2 | | | * |
| ac | 3-4 | | | * |
| bc | 5-6 | | | * |
| ac | 7-8 | | | * |
| ao | 9-10 | | | * |
| bc | 11-12 | | | * |
| ao | 13-14 | | | |
| bc | 15-16 | | | |
| a % | 17-18 | | | |
| b % | 19-20 | | | |
| a % | 21-22 | | | |
| b % | 23-24 | | | |
| b % | 25-26 | | | |
| a % | 27-28 | | | |
| b % | 29-30 | | | |
| a % | 31-32 | | | |
| tc | 35-36 | OPENS ON OVERLOAD ON CLOSE STROKE | | * |
| to | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE | | * |

CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

| | | | | |
|--|-----------------------|--|--|-----------------------------------|
| EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R.K. CH. VALKONINIS DATE JUNE 8, 1978 | | WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CROSSOVER FROM ECCS EQUIP A EXHAUST VA 2PV-01385B | | WPPS-3240 D-6001 SHEET 2862 |
| 5 4 3 12-29-81 2 9-11-81 1 5-20-80 | REV. DATE BY APPROVED | NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS 1 | | |

RIDS

8303030334

