



LIMIT SW DEVELOPMENT			
EMASCO SYMBOL	CONT.	VALVE OPNG. %	QWD SH.
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
--- CONT. CLOSED * THIS SHEET			

PRC APERTURE CARD

MOV LIMIT SW-5

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS 1

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. VALKSNINIS DATE JULY 23 1978				WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO 3 & 5 CONTROL WIRING DIAGRAM CONTROL ROOM, C. A. T. ISOL. VA 31V-BT6154				WPPSS-3240 D-6001 SHEET 2899	
REV.	DATE	BY	APPROVED	APPROVED <i>D.J. Quico</i> <i>C. Downing</i>					

66 14

66 14

66 58

66 14

66 14

66 58

66 58

66 11

66 17

RIDS

8303030421

