



NOTE  
I. JUMPER BY FIELD.

LIMIT SW DEVELOPMENT			
SYMBOL	CONT.	VALVE OPNS. %	COND.
ba	1-2		
bc	3-4		
bd	5-6		
be	7-8		
bf	9-10		
bg	11-12		*
bc	13-14		*
bd	15-16		*
be	17-18		
bf	19-20		
bg	21-22		
ba	23-24		
bb	25-26		
bc	27-28		
bd	29-30		
be	31-32		
1c	35-36	OPEN ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPEN ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED \* THIS SHEET

PRO  
APERTURE  
GARD

**NUCLEAR SAFETY PROJECT**      **WPPSS QUALITY CLASS I**

<b>ERASCO SERVICES INCORPORATED</b>	<b>WASHINGTON PUBLIC POWER SUPPLY SYSTEM</b>	<b>WPPSS-3</b>	<b>D-6001</b>
SW. CONTROL BY A.M.	APPROVED	<b>NUCLEAR PROJECTS NO. 3 &amp; 5</b>	<b>REV. 2901</b>
EN. V. ALKINIS	<i>[Signature]</i>	<b>CONTROL WIRING DIAGRAM</b>	
DATE JULY 28, 1978	<i>[Signature]</i>	<b>CONTROL ROOM SMOKE PURGE INTAKE</b>	
		<b>ISOL V4 3PW-B1578</b>	



RIDS

8303030428

