



NOTE
I. JUMPER BY FIELD.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CND. SM.
bc	1-2	0	*
ac	3-4	100	*
bc	5-6	0	*
ac	7-8	100	*
ac	9-10	0	*
bc	11-12	0	*
ac	13-14	100	*
bc	15-16	0	*
a %	17-18	0	*
b %	19-20	0	*
a %	21-22	0	*
b %	23-24	0	*
b %	25-26	0	*
a %	27-28	0	*
b %	29-30	0	*
a %	31-32	0	*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

MOV LIMIT SW'S

NUCLEAR SAFETY RELATED

WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED
 DIV. CONTROL OR A.M.
 GEN. V. ALKSNINIS
 DATE JULY 28, 1978

APPROVED
 [Signature]

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 5 & 6
 CONTROL WIRING DIAGRAM
 CONTROL ROOM SMOKE PURGE EXHAUST
 ISOL VALVE 3PV-B0345A

WPPS-324C
 D-6001
 SHEET 2904

