



NOTE
1. JUMPER BY FIELD.

PRC
APERTURE
CARD

LIMIT SW DEVELOPMENT			
ERASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bc	1-2		*
ac	3-4		*
bc	5-6		*
ac	7-8		*
ac	9-10		*
bc	11-12		*
ac	13-14		*
bc	15-16		*
ac	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
o %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED * THIS SHEET

ERASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. VALKSNINIS DATE JULY 28, 1978		APPROVED <i>D. Price</i> DATE	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTROL ROOM SMOKE PURGE EXHAUST ISCL VA 57V-B1345B	WPPSS-3240 D-6001 SHEET 2905
---	--	-------------------------------------	--	------------------------------------

FORM NO 1288 91-76 45895

RIDS

8393030477

