



LIMIT SW DEVELOPMENT

EMASCO SYMBOL	CONT.	VALVE OPNS. %	OPD SH.
bo	1-2		*
bc	3-4		*
bo	5-6		*
bc	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EMASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. V. ALKSNINIS DATE JULY 28, 1978	APPROVED DATE	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTROL ROOM O. A. I. ISOL. VA. 3PV-9 0635/	WPPSS-3240 D-0001 SHEET 2923
--------------------------------------------------------------------------------------------------------	----------------------	-------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------

KIDS

8303030485

