



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
bc	1-2	0	*
ac	3-4	100	*
bc	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
10	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
10	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED		WPPSS QUALITY CLASS I	
EDASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
DIV. CONTROL DR. A.M.		NUCLEAR PROJECTS NO. 3 & 4	
CH. V. ALKSNINIS		CONTROL WIRING DIAGRAM	
DATE JULY 28, 1978		CONTROL ROOM SMOKE PURGE INTAKE	
ISOL VA 3PV-R0365A		WPPS-3240	
SHEET 2925		D-6001	

REV.	DATE	BY	APPROVED
1	4-8-82	RJP	V.A.
2	5-23-80	NA	NA

APPROVED
 [Signature]
 [Signature]

66 14

66 11

66 98

66 11

66 11

66 98

8.5"

11"

17"

