



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	100
bc	1-2		*
ec	3-4		*
bc	5-6		*
cc	7-8		*
cc	9-10		*
bc	11-12		*
bc	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
a %	25-26		*
b %	27-28		*
a %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1c	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

NUCLEAR SAFETY RELATED      WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL OR A.M. GM. V. ALKSHINIS DATE JULY 28, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CONTROL ROOM SMOKE PURGE INTAKE ISOL VA 3FV-B:263B		WPPSS-324C D-6001 SHEET 2926
--	--	--	--	------------------------------------

FIG 13 1250 1174 0003A

RIDS

8303030488

