



LIMIT SW DEVELOPMENT			
EDASCO SYMBOL	CONT.	VALVE OPNG %	CWD SH.
bc	1-2	0	100
ac	3-4		
bo	5-6		
oc	7-8		
oo	9-10		
bc	11-12		
oo	13-14		
bc	15-16		
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
a %	25-26		
b %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
CONT. CLOSED			* THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS I

EDASCO SERVICES INCORPORATED  
 DIV. CONTROL DR. A.M.  
 CH. VALKSNINIS  
 DATE JULY 28, 1978

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECTS NO. 3 & 5  
 CONTROL ROOM EXHAUST  
 ISOL VALVE-B062SA

WPPS-224G  
 D-6001  
 SHEET 2927

14

11

10

8.5"

11"

17"

11

11

9.8

8.5"

11"

17"



