



LIMIT SW DEVELOPMENT

| EBASCO SYMBOL | CONT. | VALVE OPNG. % | | CWD SH. |
|---------------|-------|-----------------------------------|-----|---------|
| | | 0 | 100 | |
| bo | 1-2 | | | * |
| bc | 3-4 | | | * |
| bc | 5-6 | | | * |
| ac | 7-8 | | | * |
| ac | 9-10 | | | * |
| bc | 11-12 | | | * |
| do | 13-14 | | | * |
| bc | 15-16 | | | * |
| a % | 17-18 | | | * |
| b % | 19-20 | | | * |
| a % | 21-22 | | | * |
| b % | 23-24 | | | * |
| b % | 25-26 | | | * |
| a % | 27-28 | | | * |
| b % | 29-30 | | | * |
| a % | 31-32 | | | * |
| 1c | 35-36 | OPENS ON OVERLOAD ON CLOSE STROKE | | * |
| 1o | 45-46 | OPENS ON OVERLOAD ON OPEN STROKE | | * |

--- CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WFPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED
 DIV. CONTROL CR. A.M.
 CH. V. ALKSNINIS
 DATE JULY 28, 1978
 APPROVED
 [Signature]
 [Signature]

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 CONTROL ROOM EXHAUST
 ISOL VA 3FV-B162SB

WFPSS-324C
 D-6001
 SHEET 2928

REV. DATE BY APPROVER

FIG 78 TBS 11-74 05870

RIDS

830303Q491

