



NOTE
1. JUMPER BY FIELD.

LIMIT SW DEVELOPMENT			
SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
ba	1-2	0	
ac	3-4	100	
bc	5-6		
ao	7-8		
bc	9-10		
bc	11-12		
ao	13-14		
bc	15-16		
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	1c
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	1a

CONT. CLOSED * THIS SHEET

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EDASCO SERVICES INCORPORATED
 DIV. CONTROL DR. A.M.
 CH. V. ALKSNINIS
 DATE JULY 28 1978

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO'S 8 & 9
 CONTROL ROOM SMOKE PURGE EXHAUST
 ISOL VA 3PV-B1355B

WPPS-3240
 D-0001
 SHEET 2930

REV. DATE BY APPROVED

R

