



NOTE  
1. CONTACT CLOSE ON ESCW EXP TANK A(SA) HIGH RATE OF CHANGE.

LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	CWD SH.
		0	100
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*
		CONT. CLOSED	* THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED			
REV.	DATE	BY	APPROVED
6-7-82			
12-23-81			
5-23-80			
DATE OCT. 9, 1978		APPROVED	

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
 NUCLEAR PROJECTS NO. 1 & 5  
 CONTROL WIRING DIAGRAM  
 ESSENTIAL SERVICES CHILLED WATER  
 NON ES CW ISOL VALVE-80035A

WPPSS-3240  
 D-6001  
 SHEET 2943

RIDS

8303030503

