



LIMIT SW DEVELOPMENT

EBASCO SYMBOL	CONT.	VALVE OPNG. %		CWD SH.
		0	100	
bo	1-2			*
ac	3-4			*
bc	5-6			*
ac	7-8			*
oo	9-10			*
bc	11-12			*
oo	13-14			*
bc	15-16			*
a %	17-18			*
b %	19-20			*
a %	21-22			*
b %	23-24			*
a %	25-26			*
a %	27-28			*
b %	29-30			*
a %	31-32			*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

--- CONT. CLOSED * THIS SHEET

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. V. ALKSNINIS REV. DATE BY APPROVED 12-23-81 FM VA [Signature] 4-23-80 [Signature]		APPROVED [Signature] DATE OCT 9, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM ESSENTIAL SERVICES CHILLED-WATER CONTAINMENT ISOL. VALVE - B0105A	WPPS-3240 D-6001 REV. 2945
--	--	---	--	---	---

14

11

11

11

11

17

11

11

11

8.5"

11"

17"

RIDS

8303030507

